

Owner / Applicant Information

Tavana Brown

2581 E 2070 RD

HUGO OK 74743

Phone 5803269229

Email ROADOFFICE@KELLYMILLERCIRCUS.COM

Designer Information

Patrick Neihaus

Clark Reder Engineering

10091 Mosteller Lane

West Chester OH

Phone 5138511223

Email jreder@clarkreder.com

Project Information

Kelly Miller Circus
1067 Wabash Ave.

Clinton 47842

County VERMILLION

Project Type New Addition Alteration Existing Change of Occupancy

Project Status U F=Filed U or Null=Unfiled

IDHS Issued Correction order? No Has Violation been Issued? No

Violation Issued by: NA

Local Building Official

Phone:

Email:

Local Fire Official

Phone:

Email:

Variance Details

Code Name: 2014 IFC
3103.8.2

Conditions:

DEMONSTRATION THAT PUBLIC HEALTH, SAFETY, AND WELFARE ARE PROTECTED:

1

1=Non-compliance with the rule will not be adverse to the public health, safety or w

2= Applicant will undertake alternative actions in lieu of compliance with the rule to ensure that granting of the variance will not be adverse to public health, safety, or welfare. Explain why alternative actions would be adequate (be specific).

Facts:

DEMONSTRATION OF UNDUE HARDSHIP OR HISTORICALLY SIGNIFICANT STRUCTURE:

Imposition of the rule would result in an undue hardship (unusual difficulty) because of physical limitations of the construction site or its utility services.

Y

Imposition of the rule would result in an undue hardship (unusual difficulty) because of major operational problems in the use of the building or structure.

Imposition of the rule would result in an undue hardship (unusual difficulty) because of excessive costs of additional or altered construction elements.

Imposition of the rule would prevent the preservation of an architecturally or a historically significant part of the building or structure

Facts: